



Connection Technology Center
7939 Rae Blvd
Victor, NY 14564
(585) 924-5900

12/16/2025

Safety Integrity Level (SIL) Certificate of Compliance

The following parts mentioned are suitable for use in safety related systems up to and including SIL 2 in accordance with IEC 61508. The mean time to failure was calculated using the IEC 62380 protection method. Since the mode of operation is continuous, failures per hour is used to determine the Safety Integrity Level (SIL).

Parts tested:

Part Number	Description	Failures/Hour
LP584 SERIES	Loop Power Sensor, 4-20 mA Output Proportional to Vibration in Velocity, Side Exit Connector/Cable	3.00092E-07

Certified by

Charlotte Cook
Director of Engineering