



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX CSA 24.0015X** Page 1 of 4 [Certificate history:](#)
Issue 0 (2024-12-11)

Status: **Current** Issue No: 1

Date of Issue: 2026-04-23

Applicant: **CTC - Connection Technology Center, Inc.**
7939 Rae Blvd.
Victor
New York 14564
United States of America

Equipment: **AC93*~***, AC94*~***, AC95*~***, LP82*~***, LP92*~***, TA93*~***, VE80*~***, LPH82*~***, LPH92*~*** Series
Transducer Sensors.**

Optional accessory:

Type of Protection: **Increased safety "ec" and dust protection "tc"**

Marking: Ex ec IIC T°C Gc
Ex tc IIIC T135°C Dc

T4 for ambient temperature range of -40°C to +80°C
T3 for ambient temperature range of -40°C to +121°C
T135°C for ambient range of -40°C to +80°C

*Temperature Class depends on the ambient temperature

Approved for issue on behalf of the IECEx
Certification Body:

Dave Magee

Position:

Senior Director of Operations

Signature:
(for printed version)

Date:
(for printed version)

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

CSA Group
178 Rexdale Boulevard
Toronto, Ontario M9W 1R3
Canada





IECEX Certificate of Conformity

Certificate No.: **IECEX CSA 24.0015X**

Page 2 of 4

Date of issue: 2026-04-23

Issue No: 1

Manufacturer: **CTC - Connection Technology Center, Inc.**
7939 Rae Blvd.
Victor
New York 14564
United States of America

Manufacturing locations: **CTC - Connection Technology Center, Inc.**
7939 Rae Blvd.
Victor
New York 14564
United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-31:2022](#) Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure "t"
Edition:3.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[CA/CSA/ExTR24.0033/00](#)

[CA/CSA/ExTR24.0033/01](#)

Quality Assessment Report:

[CA/CSA/QAR08.0011/13](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX CSA 24.0015X**

Page 3 of 4

Date of issue: 2026-04-23

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

General Product Description:

Vibration sensors which are used for acceleration measurement by means of piezo-electric device. The piezoelectric is subjected to compression pressure from a mass which produce a voltage in proportion to the acceleration. The voltage is then amplified by internal electronic circuitry. This can also be integrated within the amplifier board to produce a velocity output, referred to with a VE prefix. For the Loop Power and Premium Loop Power series (LP/LPH prefix), the output is converted to a 4-20 mA. These sensors can be used in conjunction with a temperature board to provide the temperature of the environment the sensor is contained within this configuration is referred to with a TA prefix. The sensors are mounted to the surface of the desired surface via a threaded bolt or by other means to be approved of by the authority having jurisdiction.

See annexe for further information.

Conditions of Manufacture

1. The equipment shall be subjected to dielectric strength test using test voltage of 500 VAC applied between circuit and earth for 60 seconds. Alternatively, a voltage of 20% higher may be applied for 1 second. There shall be no evidence of flashover or breakdown and the maximum current flowing during the test shall not exceed 5 mA r.m.s. at any time. Refer to IEC 60079-7:2017 Ed. 5.1 clause 7.1.
2. Cables of the following CTC part numbers CB190, CB191 and CB192 are restricted only for use with sensors of a maximum ambient temperature of + 80°C, the manufacturer shall ensure that the product is marked accordingly.

SPECIFIC CONDITIONS OF USE: YES as shown below:

1. Cables of the following CTC part numbers CB190, CB191 and CB192 are restricted only for use with sensors of a maximum ambient temperature of + 80°C, the manufacturer shall ensure that the product is marked accordingly.
2. Temperature code depends on the ambient range: T4 for ambient range of -40°C to +80°C and T3 for ambient range of -40°C to +121°C.
3. The sensors have to be used with the cables, offered and sold by the manufacturer.
4. For applications in explosive dust atmospheres the equipment must not be exposed to charge generating mechanisms as flow of particles, charge spraying or strong electrostatic fields.



IECEX Certificate of Conformity

Certificate No.: **IECEX CSA 24.0015X**

Page 4 of 4

Date of issue: 2026-04-23

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Issue 1 – this Issue introduced the following changes:

1. Addition of Premium Loop Powered Sensors, models LPH82*-***, LPH92*-***.
2. Addition of two alternative encapsulants.
3. Addition of alternative cable molding materials, polycarbonate and nylon.

Annex:

[IECEX CSA 24.0015X Annexe Issue 1.pdf](#)

Annexe to: IECEx CSA 24.0015X Issue 1

Applicant: CTC - Connection Technology Center, Inc.



Apparatus: AC93*-*-* , AC94*-*-* , AC95*-*-* , LP82*-*-* , LP92*-*-* , TA93*-*-* , VE80*-*-* , LPH82*-*-* , LPH92*-*-* Series Transducer Sensors.

EQUIPMENT (continued)

In terms of connectors and cables, there could be Various wiring configurations:

Model types	Connector type		
	Connector with 2 pins and 2 wire cables	Connector with 3 pins and 3 wire cables	Connector with 4 pins and 4 wire cables
AC93*-* Series - Low Capacitance Accelerometer (schematic INS10053) AC94*-* Series - Compact Accelerometer (schematic INS10048) VE80* Series - Velocity Sensor (schematic INS10074)	1 wire is for the sensing element and 1 common/ground.	N/A	N/A
AC949-XR Biaxial Accelerometer (schematic INS10048)	N/A	2 wires are for the different sensing elements and 1 common.	N/A
TA93* Series - Dual Output Accelerometer with Temperature INS10049+ INS10053	N/A	1 wire is for signal, 1 for temperature, 1 shared common	N/A
AC950-XR Triaxial Accelerometer (schematic INS10048)	N/A	N/A	3 wires are for the different sensing elements and 1 common.
LP82*-* Series - Loop Power Velocity Sensor (schematic INS10026) LP92*-* Series - Loop Power Accelerometer (schematic INS10026) LPH82*-* Series – Premium Loop Power Velocity Sensor (schematic INS10179) LPH92*-* Series – Premium Loop Power Acceleration Sensor (schematic INS10179)	1 wire is for loop power and 1 wire is for loop power return	N/A	N/A

The construction of the cables with their assembly are shown on INS10196 connectors.

Part Number	Conductor Count	Cable Jacketing	Temperature Range
CB102	Two (2) Conductors	FEP Jacket	150
CB111	Two (2) Conductors	FEP Jacket	150
CB190	Two (2) Conductors	TPE Jacket	105
CB206	Two (2) Conductors	FEP Jacket with SS Armor	150
CB212	Three (3) Conductors	FEP Jacket with SS Armor	150
CB191	Three (3) Conductors	TPE Jacket	105

Date: 23 April 2026

Page 1 of 2

Annexe to: IECEx CSA 24.0015X Issue 1

Applicant: CTC - Connection Technology Center, Inc.



Apparatus: AC93*-***, AC94*-***, AC95*-***, LP82*-***, LP92*-***, TA93*-***, VE80*-***, LPH82*-***, LPH92*-*** Series Transducer Sensors.

Part Number	Conductor Count	Cable Jacketing	Temperature Range
CB192	Four (4) Conductors	TPE Jacket	105
CB218	Four (4) Conductors	FEP Jacket with SS Armor	200
CB296	Two (2) Conductors	FEP Jacket with SS Armor	200
CB298	Four (4) Conductors	FEP Jacket with SS Armor	200

For models without integral cables, a cable should be used as per INS10125 with a temperature rating of at least 105°C.

Connector P/N Q Series Q** where the first asterisk "*" is the number of pins (2 or 3) and the second asterisk is the type of the moulding material represented by the letter below:

- "R": Polyphenylene Sulphide, (PPS), or
- "A": Polycarbonate, or
- "N": Nylon

There is another 4 pins connector P/N JQ4* as described in drawing INS10196 with approved cables manufactured by CTC, temperature ratings 105°C or CB218, CB298 manufactured by CTC, temperature ratings 200°C containing a S500 -70 Silicone compound made O-ring, manufactured by Boyd Corp. ID: 7/16 by OD: 9/16 inch, 70A durometer, -50 to +240°C operation temperature

The insulator material use in the Cable Connector is Ryton R-4-230 which is a Polyphenylene Sulphide (PPS) material mentioned on the INS10120 connector drawing. It has an RTI (Imp and Elec) of 200°C for the material thickness of 0.71mm which in this case is thicker than that.